



PLAN VIEW
N.T.S.

NOTES:

1. REFER TO GS 1.5 FOR MINIMUM HORIZONTAL AND VERTICAL CLEARANCES.
2. BACK FLOW PREVENTOR SHALL BE INSTALLED IN ACCORDANCE WITH THE DEPARTMENT'S SPECIFICATIONS.
3. PREFERRED ARRANGEMENT SHOWN FOR WATER AND RECLAIMED WATER SERVICES.
4. WHERE THE DRIVEWAY IS NOT CENTERED ON THE PROPERTY, THE RECLAIMED WATER MAIN SHALL BE PLACED AS FAR AWAY FROM THE POTABLE WATER MAIN AS PRACTICABLE, AND IN COMPLIANCE WITH GS 1.5.

ITEM	CROSS REF.	SPEC. REF.



ISSUE DATE	APPROVED BY
06/01/2008	V.E.F.

STANDARD DETAIL
TYPICAL RESIDENTIAL UTILITY
LAYOUT
SINGLE SERVICE CONNECTIONS

R
2.0
SHEET 1 OF 1