










**LOCATION OF PUBLIC WATER SYSTEM MAINS ACCORDANCE WITH F.A.C. RULE 62-555.314**

OTHER PIPE	HORIZONTAL SEPARATION	CROSSINGS (1)	JOINT SPACING @ CROSSINGS (FULL LENGTH OF PIPE CENTERED)
Storm Sewer; Stormwater Force Main; Reclaimed Water (2)	 <p>Water Main 3 ft. minimum</p>	 <p>Water Main 12 inches is the minimum.</p>	 <p>Alternate: 3 ft minimum</p>
Vacuum Sanitary Sewer	 <p>Water Main 10 ft. preferred 3 ft. minimum</p>	 <p>Water Main 12 inches preferred 6 inches minimum</p>	 <p>Alternate: 3 ft minimum</p>
Gravity or Pressure; Sanitary Sewer; Sanitary Sewer Force Main; Reclaimed Water (4)	 <p>Water Main 10 ft. preferred 6 ft. minimum (3)</p>	 <p>Water Main 12 inches is the minimum.</p>	 <p>Alternate: 6 ft minimum</p>
On-Site Sewage Treatment & Disposal System	10 ft minimum	-	-

**NOTES:**

- (1) WATER MAIN SHOULD BE ABOVE OTHER PIPE. WHEN WATER MAIN MUST BE BELOW OTHER PIPE, THE MINIMUM SEPARATION IS 12 INCHES.
- (2) RECLAIMED WATER REGULATED UNDER PART III OF CHAPTER 62-610, F.A.C.
- (3) 3 FT. GRAVITY SANITARY SEWER WHERE THE BOTTOM OF THE WATER MAIN IS LAID AT LEAST 6 INCHES ABOVE THE TOP OF THE GRAVITY SANITARY SEWER.
- (4) RECLAIMED WATER NOT REGULATED UNDER PART III OF CHAPTER 62-610, F.A.C.

I T E M	CROSS REF.	SPEC. REF.



ISSUE DATE	APPROVED BY
10/1/2017	D.V.

STANDARD DETAIL  
**POTABLE WATER MAIN,  
WASTEWATER & STORM SEWER CONFLICT**

**GS  
1.5  
SHEET 1 OF 2**