




NOTES:

1. BACKGROUND OF SIGN SHALL BE WHITE (RECLAIMED WATER LINES SHALL BE PANTONE PURPLE 522C), BORDER AND LETTERS SHALL BE BLACK HELVETICA, SWISS 721 COREL OR APPROVED EQUAL, WITH THE EXCEPTION OF THE WORD WARNING WHICH SHALL BE IN RED REFLECTIVE PAINT MATERIAL AND THE MIAMI-DADE LOGO WHICH SHALL BE GREEN AND BLUE PAINT, AS SHOWN ON THE DETAIL.
2. ENGINEERING GRADE REFLECTIVE MATERIALS SHALL BE USED.
3. SIGN MATERIAL SHALL BE OF 14 GAUGE ANODIZED ALUMINUM.

SUB-AQUEOUS PIPELINE CROSSING SIGNAGE		01581
ITEM	CROSS REF.	SPEC. REF.

 WATER & SEWER DEPARTMENT	ISSUE DATE	APPROVED BY	STANDARD DETAIL SIGN DETAILS ENGLISH, SPANISH AND CREOLE	GS 4.0 SHEET 1 OF 2
	01/05/2010	V.F.C.		
	07/20/2016	D.V.		