

NOTES:

- 1-. THE ASSEMBLY SHALL BE INSTALLED WITH MINIMUM HORIZONTAL CLEARANCES OF 30 INCHES FREE FROM OBSTRUCTIONS IN ALL DIRECTIONS.
- 2-. GUARD POSTS SHALL BE INSTALLED IF THE ASSEMBLY IS EXPOSED TO POSSIBLE DAMAGE FROM VEHICULAR TRAFFIC, AS DETERMINED BY THE DEPARTMENT.
- 3-. THE ASSEMBLY SHALL BE INSTALLED IN AN ACCESSIBLE LOCATION, APPROVED BY THE DEPARTMENT.
- 4-. ADJUSTABLE PIPE SADDLE SUPPORT (GRINNELL FIG. 264, OR EQUAL) SIZED TO FIT CURVATURE OF DOUBLE DETECTOR CHECK VALVE ASSEMBLY, WITH GALVANIZED STEEL PIPE AND FLOOR FLANGE. ATTACH FLOOR FLANGE TO CONCRETE SLAB WITH GALVANIZED EXPANSION BOLTS.
- 5-. THE DEPARTMENT SHALL HAVE UNRESTRICTED AND CONTINUOUS ACCESS TO THE BACKFLOW PREVENTION ASSEMBLY.
- 6-. PIPING 2" AND SMALLER SHALL BE SCHEDULE 40 BRASS OR TYPE K COPPER PIPE WITH FITTINGS. PIPING 4" AND LARGER SHALL BE DUCTILE IRON PIPE WITH FLANGED FITTINGS. ALL PIPING SHALL BE IN ACCORDANCE WITH WASD CONSTRUCTION SPECIFICATIONS FOR DONATION WATER MAINS, PVC PIPING IS NOT ACCEPTED BY WASD.
- 7-. ALL OUTLETS SHALL BE PLUGGED WITH BRASS PLUGS.
- 8-. ALL ABOVE GROUND PIPING AND EQUIPMENT, EXCEPT FOR BRASS AND STAINLESS STEEL PORTIONS, SHALL BE FINISHED WITH BLUE ENAMEL PAINT (KOP-COAT 0508 LEAD-FREE) IN ACCORDANCE WITH DEPARTMENT STANDARDS.
- 9.- COPPER ALLOY MATERIALS SHALL BE "LEAD FREE" AND IN FULL COMPLIANCE WITH THE FEDERAL "REDUCTION OF LEAD IN DRINKING WATER ACT".
- 10-. FOR A LIST OF BACKFLOW PREVENTERS APPROVED TO BE USED IN WASD FACILITIES, REFER TO PRE-APPROVED PRODUCT LIST SHEET NUMBER 4.6 AND/OR THE UNIVERSITY OF SOUTHERN CALIFORNIA FOUNDATION LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES AT WWW.USCLIST.COM. OR fccchr.usc.edu/list.html

GUARD POST DETAIL	WS 4.5	
ITEM	CROSS REF.	SPEC. REF.

	<u>ISSUE DATE</u>	<u>APPROVED BY</u>	STANDARD DETAIL REDUCED PRESSURE ZONE BACKFLOW PREVENTER FOR WATER SERVICE - NOTES -	WS 4.18 SHEET 3 OF 3
	8/29/2012	F.A.		
	3/22/2022	S.G.		